

Notice of Surface Water Treatment Technique Violation (Daily)

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The City of Throckmorton failed to meet the minimum treatment technique requirements on August 2015. Specifically, our water system failed to properly disinfect the drinking water for a period of more than 4 hours and allowed the disinfectant residual of the water entering the distribution system to fall below the acceptable level for more than four hours.

If you want more information about the nature and significance of this violation, you may contact Will Carroll, Mayor @ 940-849-4411.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.